



ZIONSVILLE WASTE WATER DEPARTMENT
MONTHLY REPORT

	<u>NOVEMBER 2014</u>	<u>NOVEMBER 2013</u>
TOTAL FLOW	27.78 MG	29.91 MG
HIGHEST DAILY FLOW	2.184 MG	1.705 MG
AVERAGE DAILY FLOW	0.926 MG	0.997 MG
PRECIPITATION	3.65 in	5.7 in
NPDES VIOLATIONS	0	0
PERCENT FLOW CAPACITY	46%	50%

ADDITIONAL COMMENTS:

- The 2014 Sewer Rehabilitation Project is substantially complete. A punch list will be compiled that details the remaining work such as televising, as-builts, and yard restoration. Yard restoration cannot be completed until this coming spring.
- The Quail Run Force Main Project from the new apartment complex, down the rail trail, and connected to the Main Lift Station Force place is nearly complete with pressure testing, as-builts, and property restoration still remaining.

